



WHITEHAVEN CHPP – MONTHLY MONITORING SUMMARY

Site Information

EPL No: 3637

EPA Website Link: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33514&SYSUID=1&LICID=3637>

Licensee: Whitehaven Coal Mining Limited

Licensee Address: Boggabri Road, Gunnedah NSW 2380

EPL Monitoring Points: See Figure 1 below

Sampling Period: July 2025

Obtained Date: 11th August 2025

Publication Date: 11th August 2025

Table 1 - No Pollutant Limits Apply

EPL ID	Pollutant	Units of Measure	Monitoring Frequency	No. of Measurements for the Month	Date Sampled	Date Obtained	Min Value	Mean Value	Median Value	Max or Only Value
3	Solid Particles	g/m ² /month	Continuous	1	07/07/2025	31/07/2025	-	-	-	0.7
11	PM ₁₀ Kendo	µg/m ³	Every 6 days	5	05/07/2025 11/07/2025 17/07/2025 23/07/2025 29/07/2025	11/08/2025 (Last sampled received)	2.20	8.48	5.90	18.60
12	PM ₁₀ Olive View	µg/m ³	Every 6 days	5	05/07/2025 11/07/2025 17/07/2025 23/07/2025 29/07/2025	11/08/2025 (Last sampled received)	5.30	8.38	7.50	12.70
6	Conductivity	µs/cm	Each overflow event	0	-	-	-	-	-	-
	Oil and Grease	mg/L					-	-	-	-
	Total Organic Carbon	mg/L					-	-	-	-
	Total Suspended Solids	mg/L					-	-	-	-
	pH	pH					-	-	-	-
7	Conductivity	µs/cm	Quarterly (Feb, May, Aug, Nov)	-	-	-	-	-	-	-
	Oil and Grease	mg/L					-	-	-	-
	Total Organic Carbon	mg/L					-	-	-	-



WHITEHAVEN CHPP – MONTHLY MONITORING SUMMARY

EPL ID	Pollutant	Units of Measure	Monitoring Frequency	No. of Measurements for the Month	Date Sampled	Date Obtained	Min Value	Mean Value	Median Value	Max or Only Value
	Total Suspended Solids	mg/L					-	-	-	-
	pH	pH					-	-	-	-

Table 2 – Groundwater Monitoring (Quarterly – No Limits apply)

EPL ID	Pollutant	Units of Measure	Monitoring Frequency	No. of Samples for the Period	Date Sampled	Date Obtained	Min Value	Mean Value	Median Value	Max or Only Value
8	Ammonia	mg/L	Quarterly (P1) (Mar, Jun, Sep, Dec)	1*	28/07/2025	04/08/2025	-	-	-	0.48
	Bicarbonate	mg/L					-	-	-	<1
	Calcium	mg/L					-	-	-	70
	Chloride	mg/L					-	-	-	1920
	Conductivity	µs/cm					-	-	-	9760
	Lead	mg/L					-	-	-	<0.001
	Magnesium	mg/L					-	-	-	176
	Nitrate	mg/L					-	-	-	1.49
	Potassium	mg/L					-	-	-	25
	Sodium	mg/L					-	-	-	2170
	Standing Water Level	m					-	-	-	6.68
	Sulphate	mg/L					-	-	-	1060
	pH	pH					-	-	-	8.15
9	Ammonia	mg/L	Quarterly (P2) (Mar, Jun, Sep, Dec)	1*	28/07/2025	04/08/2025	-	-	-	2.14
	Bicarbonate	mg/L					-	-	-	<1
	Calcium	mg/L					-	-	-	295
	Chloride	mg/L					-	-	-	1010

WHITEHAVEN CHPP – MONTHLY MONITORING SUMMARY

EPL ID	Pollutant	Units of Measure	Monitoring Frequency	No. of Samples for the Period	Date Sampled	Date Obtained	Min Value	Mean Value	Median Value	Max or Only Value
	Conductivity	µs/cm					-	-	-	5870
	Lead	mg/L					-	-	-	<0.001
	Magnesium	mg/L					-	-	-	220
	Nitrate	mg/L					-	-	-	0.04
	Potassium	mg/L					-	-	-	122
	Sodium	mg/L					-	-	-	712
	Standing Water Level	M					-	-	-	1.43
	Sulphate	mg/L					-	-	-	654
	pH	pH					-	-	-	6.96
10	Ammonia	mg/L	Quarterly (P3) (Mar, Jun, Sep, Dec)	1*	28/07/2025	04/08/2025	-	-	-	3.07
	Bicarbonate	mg/L					-	-	-	<1
	Calcium	mg/L					-	-	-	240
	Chloride	mg/L					-	-	-	1270
	Conductivity	µs/cm					-	-	-	6020
	Lead	mg/L					-	-	-	<0.001
	Magnesium	mg/L					-	-	-	212
	Nitrate	mg/L					-	-	-	2.58
	Potassium	mg/L					-	-	-	62
	Sodium	mg/L					-	-	-	733
	Standing Water Level	M					-	-	-	1.02
	Sulphate	mg/L					-	-	-	260
	pH	pH					-	-	-	7.43

*Sample was taken in June however was re-sampled in July due to lab analysis error.



WHITEHAVEN CHPP – MONTHLY MONITORING SUMMARY

Table 3 – Monitoring (Quarterly Noise – Limits Apply)

(Mar, Jun, Sep, Dec)

EPL ID	Date	Measurement Period	Measured levels – CHPP – dB(A)		Limit(s)- dB(A)	Wind speed (m/s)	Observations	(Potential) Non-compliance /breach
			LA1, 1 minute	LAeq, 15 minute				
N1	-	15 mins day	-	-	35	-	-	-
		15 mins evening	-	-	35	-	-	
		15 mins night	-	-	35	-	-	
		1 min night	-	-	45		-	

Notes:

dB(A): The overall level of a sound is usually expressed in terms of dBA, which is measured using a sound level meter with an “A-weighting” filter. This is an electronic filter having a frequency response corresponding approximately to that of human hearing.

LAeq, 15 minute: The A-weighted equivalent noise level (basically the average noise level). It is defined as the steady sound level that contains the same amount of acoustical energy as the corresponding time-varying sound, in this instance over a period of 15 minutes.

LA1, 1 minute: The noise level exceeded for 1% of the 15 minute interval.

I/A: When site noise is noted as inaudible (I/A), no site noise was audible at the monitoring location.

Not Measurable (NM): indicates that some site noise was audible, but indeterminate due to one of the following reasons:

- site noise levels were insignificant and unlikely, in many cases, to be even noticed; or
- site noise levels were masked by another relatively loud noise source, but were estimated to be less than LAeq 30 dB, which is insignificant in terms of any applicable criterion.

WHITEHAVEN CHPP – MONTHLY MONITORING SUMMARY



WHITEHAVEN COAL

Datum MGA2020 Zone 56 Author O.Hulbert

Image Nov-22 Date Jan-23 Size/Scale 1:13000

Figure 1
Gunnedah CHPP EPL3637
Monitoring Locations

0 250 500
Meters

● CHPP_EPL_Sites_Feb23